



## ELEVATION VIEW

**NOTES:**

1. TYPICAL OPERATING RANGE:  
 1 1/2" METER - .5 TO 160 GPM  
 2" METER - .5 TO 160 GPM  
 3" METER - 1 TO 400 GPM
2. WHEN JOINING DISSIMILAR METALS  
 A WATER DEPARTMENT APPROVED  
 BRASS TRANSITION FITTING IS REQUIRED.
3. MINIMUM AREA REQUIRED FOR METER  
 SETTING 4 ft.x6 ft.x6 ft. (WXLXH)
4. TYPE "L" OR "K" COPPER PIPE WITH SOLDER  
 FITTINGS OR SCREW FITTINGS WITH BRASS  
 NIPPLES. MINIMUM DISTANCE SHOWN  
 MUST BE MAINTAINED.
5. ALL METERS ARE FLANGE ENDS.  
 BRASS FLANGES, GASKETS, AND BOLTS  
 SUPPLIED BY THE CITY OF STOW.

LAY LENGTHS	
1 1/2" METER	13 INCHES
2" METER	15 1/4 INCHES
3" METER	17 INCHES

### STANDARD METER SETTINGS FOR 1 1/2", 2" & 3" SIZES

**CITY OF STOW ENGINEERING DEPARTMENT**

DRAWN BY: TJS	APPROVED BY:
DATE: FEB. 2003	James McCleary P.E. P.S., City Engineer
<small>Checked hv</small>	